

0.075  
(14 GAUGE)

Ø0.250  
(4x)


Ⓛ (BP)

**NOTES:**

1. PANEL SHALL BE FREE FROM BURRS & SHARP EDGES
2. PANEL SHALL BE FLAT
3. PANEL SHALL BE POWDER COATED USING TIGER DRYLAC RAL 9003 49-11400 - SIGNAL WHITE OR ROBROY ENCLOSURES ENGINEERING APPROVED EQUIVALENT
4. MISALIGNED EDGES EXCEEDING 0.005" (STEPS) SHALL NOT BE PERMITTED
5. PAINT FINISH SHALL COMPLY WITH QAF-810-01-03
6. ALL EDGES SHALL BE SQUARE AND PARALLEL
7. ALL SURFACES SHALL BE CLASSIFIED AS "CLASS A" EXCEPT INTERNAL SURFACES OF ALL HOLES
8. ALL "2424" SIZE PANELS AND BELOW SHALL BE PACKAGED IN AN ENVELOPE WITH NO METAL (CLASP)
9. ALL "3020" SIZE PANELS AND ABOVE SHALL BE PACKAGED IN CARDBOARD WITH NO METAL (STAPLES)

THIS DRAWING IS THE SOLE AND EXCLUSIVE PROPERTY OF ROBROY ENCLOSURES. NO PART OF THIS DRAWING MAY BE REPRODUCED, DISTRIBUTED, OR PUBLICALLY DISPLAYED IN ANY FORM OR BY ANY MEANS WITHOUT THE EXPRESS WRITTEN PERMISSION OF ROBROY ENCLOSURES. ALL RIGHTS RESERVED. UNDER THE COPYRIGHT LAWS. COPYRIGHT © 2016 ROBROY ENCLOSURES.

**SPECIAL REQUIREMENTS**

NEMA 250: TYPE N/A IEC 60529: N/A COLOR: WHITE COLOR STANDARD: N/A		STANDARD P/N: BP1816CS	ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED	TOLERANCES UNLESS SPECIFIED	.XX ± 0.03 .XXX ± 0.010
MATERIAL: 1008/1010 PAINTED CARBON STEEL		CUSTOMER DWG:	 <p><b>Robroy Enclosures</b> 500 Maple Street Belding, Michigan 48809 Phone: 616-794-0700 Fax: 616-749-3378</p>		
REVISION HISTORY					
REV	DESCRIPTION	DATE	ENG	DRAWN BY: DRH DATE: 12/29/16 CUSTOMER: SCALE: DO NOT SCALE	
-	-	-	-	DWG: ATBP1816CS	
-	-	-	-	DESCRIPTION: STANDARD BACK PANEL	
-	-	-	-	PART NUMBER: ATBP1816CS	